

Annual Drinking Water Quality Report for 2016
Blooming Grove Water District #3
P.O. Box 358, Blooming Grove, NY 10914
(Public Water Supply ID#3503595)

INTRODUCTION

To comply with State regulations, the Blooming Grove Water District 3 (Tomahawk Lake), issues an annual water report describing the quality of our drinking water. The purpose of this report is to raise the Consumer's understanding of drinking water and awareness of the need to protect our drinking water sources. Included in this report are details about where our water comes from, what it contains, and how it compares to State standards.

If you have any questions about this report or questions concerning your drinking water, please contact our Town Engineer Anthony Eagan, P.E. at (845) 496-4177, Option #6, or the Orange County Health Department at (845) 291-2331. We want you to be informed about your drinking water. If you want to learn more, please attend any of our regularly scheduled Town Board meetings. The meetings are held the second and fourth Tuesday at 7:30 pm, at the Blooming Grove Town Hall, Horton Road & Route 94, Blooming Grove NY, 10914. The U.S.E.P.A. drinking water website (www.epa.gov/safewater) also provides additional information regarding drinking water.

WHERE DOES OUR WATER COME FROM?

The water supply for the Tomahawk Lake Water District #3 is currently provided from a single drilled bedrock well. This well is a drilled bedrock well, with a yield of approximately 21 GPM, located on Shore Drive near the community beach. The water is disinfected with chlorine prior to distribution. In 2016, our water system produced 3.831 million gallons and served 210 people.

ARE THERE CONTAMINANTS IN OUR DRINKING WATER?

In general, the sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activities. Contaminants that may be present in source water include: microbial contaminants; inorganic contaminants; pesticides and herbicides; organic chemical contaminants; and radioactive contaminants. In order to ensure that tap water is safe to drink, the State and the EPA prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. The State Health Departments and the

FDA's regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

As the State regulations require, we routinely test your drinking water for numerous contaminants. These contaminants include: chloride, ECOLI, total coliform, methylcarbamate pesticides, inorganic compounds, nitrate, nitrite, lead and copper, volatile organic compounds, PCB's, herbicide organics, and pesticide/PCB organic compounds. The table presented below depicts which contaminants were detected in your drinking water. The State allows us to test for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old.

It should be noted that all drinking water, including bottled drinking water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791) or the Orange County Health Department at (845) 291-2331. The table on the following page summarizes the results of detected compounds and their likely source.

SOURCE WATER ASSESSMENT PROGRAM (SWAP) SUMMARY

The NYS DOH has completed a source water assessment for this system, based on available information. Possible and actual threats to this drinking water source were evaluated. The State source water assessment includes a susceptibility rating based on the risk posed by each potential source of contamination and how easily contaminants can move through the subsurface to the wells. The susceptibility rating is an estimate of the potential for contamination of the source water, it does not mean that the water delivered to consumers is, or will become contaminated. See "Table of Detected Contaminants" for a list of the contaminants that have been detected. The source water assessments provide resource managers with additional information for protecting source waters into the future.

Our water is derived from a drilled well. The source water assessment has rated this well as having a medium susceptibility to microbials. This rating is due primarily to the close proximity of a pasture and the low-level residential activity that are located in the assessment area. In addition, the well draws from a confined aquifer with the estimated recharge area within the selected time of travel and the overlying soils may not provide adequate protection from potential contamination. While the source water assessment rates our well as being susceptible to microbials, please note that our water is disinfected to ensure that the finished water delivered into your home meets New York State's drinking water standards for microbial contamination.

A copy of the assessment, including a map of the assessment area, can be obtained by contacting us, as noted in this report.

WHY SAVE WATER AND HOW TO AVOID WASTING IT?

Although our system has an adequate amount of water to meet present and future demands, there are a number of reasons why it is important to conserve water:

- ◆ Saving water saves energy and some of the costs associated with both of these necessities of life;

- ◆ Saving water reduces the cost of energy required to pump water and the need to construct costly new wells, pumping systems and water towers; and
- ◆ Saving water lessens the strain on the water system during a dry spell or drought, helping to avoid severe water use restrictions so that essential fire fighting needs are met.

You can play a role in conserving water by becoming conscious of the amount of water your household is using, and by looking for ways to use less whenever you can. It is not hard to conserve water. Conservation tips include:

- ◆ Automatic dishwashers use 15 gallons for every cycle, regardless of how many dishes are loaded. So get a run for your money and load it to capacity.
- ◆ Turn off the tap when brushing your teeth.
- ◆ Check every faucet in your home for leaks.
- ◆ Just a slow drip can waste 15 to 20 gallons a day. Fix it up and you can save almost 6,000 gallons per year.
- ◆ Check your toilets for leaks by putting a few drops of food coloring in the tank, watch for a few minutes to see if the color shows up in the bowl. It is not uncommon to lose up to 100 gallons a day from one of these otherwise invisible toilet leaks. Fix it and you save more than 30,000 gallons a year.
- ◆ Use your water meter to detect hidden leaks. Simply turn off all taps and water using appliances. Then check the meter after 15 minutes. If it moved, you have a leak.

A few simple steps will preserve the resource for future generations and also save up to 30% on your bill:

- ◆ Use low flow shower heads and faucets
- ◆ Repair all leaks in your plumbing system
- ◆ Water your lawn sparingly early morning or late evening
- ◆ Do only full loads of wash and dishes
- ◆ Wash your car with a bucket and hose with a nozzle
- ◆ Don't cut the lawn too short; longer grass saves water

TABLE OF DETECTED CONTAMINANTS

Contaminant	Violation Yes/No	Date of Sample	Level Detected (Avg/Max) (Range)	Unit Measurement	MCLG	Regulatory Limit (MCL, TT or AL)	Likely Source of Contamination
Antimony	No	12/08/16	0.4	ug/L	6	MCL = 6	Corrosion of household plumbing systems, Erosion of natural deposits
Arsenic	No	12/08/16	4.2	ug/L	100	MCL = 100	Erosion of natural deposits
Barium	No	12/08/16	69	ug/L	2,000	MCL = 2,000	Erosion of natural deposits
Beryllium	No	12/08/16	0.30	ug/L	4	MCL = 4	Erosion of natural deposits
Chromium	No	12/08/16	7.0	ug/L	100	MCL = 100	Erosion of natural deposits
Cadmium	No	12/08/16	1.0	ug/L	5	MCL = 5	Erosion of natural deposits
Copper (See Note 1)	No	09/28/2012	90 th = 0.115 Range = 0.064 to 0.130	mg/L	1.3	AL = 1.3	Corrosion of household plumbing systems, Erosion of natural deposits
Cyanide	No	12/08/16	5	ug/L	200	MCL = 200	Runoff from fertilizer use
Fluoride	No	12/08/16	0.5	mg/L	2.2	MCL = 2.2	Erosion of natural deposits; water additive that promotes strong teeth
Lead (See Note 2)	No	09/28/2012	90 th = 3.65 Range = ND to 5.2	ug/L	0	AL = 15	Corrosion of household plumbing systems, Erosion of natural deposits
Mercury	No	12/08/16	0.2	ug/L	2	MCL = 2	Erosion of natural deposits
Nickel	No	12/08/16	2.7	ug/L	100	MCL = 100	Erosion of natural deposits
Nitrate	No	12/08/16	2.5	mg/L	10	MCL = 10	Runoff from fertilizer use
Sodium	No	12/08/16	110	mg/L	N/A	See Note 3	Naturally Occurring, Road Salt, Water Softeners
Selenium	No	12/08/16	13	ug/L	50	MCL = 50	Erosion of natural deposits
Sulfate	No	12/08/16	61	mg/L	250	MCL = 250	Erosion of natural deposits
Uranium	No	11/25/2014	2.4	ug/L	0	MCL = 30	Erosion of natural deposits
Thallium	No	12/08/16	0.3	mg/L	2	MCL = 2	Erosion of natural deposits
Total Trihalomethanes (TTHMs)	No	08/26/2014	9.8	ug/L	N/A	MCL = 80	By product of drinking water disinfection needed to kill harmful organisms
Five Haloacetic Acids (HAA5)	No	08/26/2014	1.4	ug/L	N/A	MCL = 60	By product of drinking water disinfection needed to kill harmful organisms

Notes:

- 1. The level presented represents the 90th percentile of the three samples collected. A percentile is a value on a scale of 100 that indicates the percent of a distribution system that is equal to or below it. The 90th percentile is equal to or greater than 90% of the copper values detected at your water system. In this case, three samples were collected at your water system and the 90th percentile value was the average of the two highest values. The action level for copper was not exceeded at any of the sites tested.*
- 2. The level presented represents the 90th percentile of the three samples collected. The action level for lead was not exceeded at any of the sites tested.*
- 3. Water containing more than 20 mg/L of sodium should not be used for drinking by people on severely restricted sodium diets. Water containing more than 270 mg/L of sodium should not be used by people on moderately restricted sodium diets.*

DEFINITIONS:

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Milligrams per liter (mg/L): Corresponds to one part of liquid in one million parts of liquid (parts per million - ppm).

Micrograms per liter (ug/L): Corresponds to one part of liquid in one billion parts of liquid (parts per billion - ppb).

WHAT DOES THIS INFORMATION MEAN?

As you can see by the table, our system had no violations. We have learned through our testing that some contaminants have been detected; however, these contaminants were detected below New York State requirements.

CLOSING

Thank you for allowing us to continue to provide your family with quality drinking water this year. In order to maintain a safe and dependable water supply we sometimes need to make improvements that will benefit all of our customers. The costs of these improvements may be reflected in the rate structure. Rate adjustments may be necessary in order to address these improvements. We ask that all our customers help us protect our water sources, which are the heart of our community. Please call our office if you have questions.

IS OUR WATER SYSTEM MEETING OTHER RULES THAT GOVERN OPERATIONS?

During 2016, our system was in compliance with applicable State drinking water operating, monitoring and reporting requirements. We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards.

DO I NEED TO TAKE SPECIAL PRECAUTIONS?

Some people may be more vulnerable to disease causing microorganisms or pathogens in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care provider about their drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium, Giardia and other microbial pathogens are available from the Safe Drinking Water Hotline (800-426-4791).

SYSTEM IMPROVEMENTS

Regular operation and maintenance procedures were implemented. In 2014-2015 all of the water mains were replaced. Additionally, all the individual water services to the users were provided including new curb shut-off valves. Design, permitting and approval for a second standby well is underway. In 2016 sequestering was implemented to address water quality issues associated with iron and manganese, in addition to regular quarterly flushing. Design, permitting and approval of a new well house is well underway and is anticipated to be completed by the end of 2017.